



NOTES

1. IT IS THE RESPONSIBILITY OF THE CONSULTANT OR CONTRACTOR, TO CONFIRM THAT THE CONTROLS SELECTION IS CORRECT PRIOR TO INSTALLATION.
2. DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS SHOULD BE CHECKED ON SITE.
3. THIS DRAWING IS FOR INDICATION ONLY.
4. ALL CONTROLS COMPONENTS SHOULD BE FITTED INSIDE A SUITABLE ENCLOSURE.
5. ALL CABLES MUST BE SIZED ACCORDING TO CURRENT WIRING REGULATIONS.

LEGEND

- L Live Wire on Indoor Unit
- N Neutral Wire
- L1 } 3 Phase Power Supply on Outdoor Unit
- L2 }
- L3 }
- A, B Remote Controller Connections
- U1, U2 System Network Connections
- U3, U4 Network Controller Connections
- U5, U6 Outdoor Network Connections

Project

Drawing Prepared For
COOL DESIGNS LTD

Drawn By

Title

Scale

NTS

TYPICAL WIRING SCHEMATIC
FOR 2 PIPE VRF UNITS
SHOWING GROUP CONTROL OFF 1 FLOW SELECTOR BOX

Date Drawn

21/05/07

CDL
Cool Designs Ltd

Cool Designs Ltd
North Hyllon Enterprise Park
Hepworth Rd
Sunderland
SR2 8BL

Tel: 01915 406 904 Fax: 01915 406 900
email: sales@cooldesignsltd.co.uk