



NOTES

1. IT IS THE RESPONSIBILITY OF THE CONSULTANT OR CONTRACTOR, TO CONFIRM THAT THE CONTROLS SELECTION IS CORRECT PRIOR TO INSTALLATION.
2. DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS SHOULD BE CHECKED ON SITE.
3. THIS DRAWING IS FOR INDICATION ONLY.
4. ALL CONTROLS COMPONENTS SHOULD BE FITTED INSIDE A SUITABLE ENCLOSURE.
5. ALL CABLES MUST BE SIZED ACCORDING TO CURRENT WIRING REGULATIONS.

LEGEND

- L Live Wire on Indoor Unit
- N Neutral Wire
- L1, L2, L3 3 Phase Power Supply on Outdoor Unit
- A, B Remote Controller Connections
- U1, U2 System Network Connections
- U3, U4 Network Controller Connections
- U5, U6 Outdoor Network Connections

Project

Drawing Prepared For
COOL DESIGNS LTD

Drawn By

Title

Scale

NTS

TYPICAL WIRING SCHEMATIC
SHOWING CONNECTION TO SATCHWELL/CYLOM/SIEMANS/ANDOVER BMS
WITH CENTRAL CONTROLLER & WEEKLY TIMER
VIA RBC-LG1/LTX51

Date Drawn
21/05/07



Cool Designs Ltd
North Hyllon Enterprise Park
Hepworth Rd
Sunderland
SR2 8BL
Tel: 01915 406 904 Fax: 01915 406 900
email: sales@cooldesignsltd.co.uk